

File No. 755

N. R. C. 139

Electricity

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, February 15, 1940.

TO DISTRICT INSPECTORS OF
ELECTRICITY AND GAS.

Re: Approval Five-Dial Register

Dear Sirs:

This is to advise you that the National Research Council approves the use of five-dial registers, manufactured by the Canadian General Electric Company, Toronto, Canada, for use on their various types of watthour meters when such a register is requested by a customer. The right-hand dial of these five-dial registers is to be a different colour from the other four dials and reads 0.1 kilowatt-hour per division without multiplier.

Yours truly,



J. L. Stiver,
Director.

JLS/mee