

Electricity

DEPARTMENT OF TRADE AND COMMERCE  
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, May 2, 1940.

TO DISTRICT INSPECTORS OF  
ELECTRICITY AND GAS.

Re: Approval of Westinghouse Types "CA" and  
"CSI" Single-phase Watthour Meters

Dear Sirs:

This is to advise you that the types "CA" and "CSI" single-phase watthour meters, manufactured by the Canadian Westinghouse Company, Hamilton, Ontario, have been approved by the National Research Council for use in Canada in the following capacities:

Amperes: 2.5, 5, 10, 15, 25, 50;

Voltages: (115, 230, 460, 575) or (120, 240, 480, 600);

Frequency: 25 and 60 cycle;

Circuits: 2- and 3-wire;

Register: Pointer and cyclometer;

Terminals: 4 and 6.

Yours truly,



J. L. Stiver,  
Director.

JLS/mee