

Electricity

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, May 2, 1940.

TO DISTRICT INSPECTORS OF
ELECTRICITY AND GAS.

Re: Approval of Sangamo Type "ED-3"
Polyphase Combination Demand
Energy Meter, 3-phase, 4-wire,
delta-connected

Dear Sirs:

This is to advise you that the type "ED-3" poly-phase combination demand energy meter, manufactured by the Sangamo Company, Limited, Toronto, Ontario, to measure power and lighting loads from a delta-connected power supply, has been approved by the National Research Council for use in Canada in the following capacities:

Amperes: 5, 10, 15, 25, 50;

Voltages: 115, 230;

Frequency: 25 and 60 cycle;

Circuits: 3-phase, 4-wire, supplied from delta-connected power transformers.

Yours truly,



J. L. Stiver,
Director.

*See Circular letter
9-40 JLS*

JLS/mee