

File No. 984

N. R. C. 145

Electricity

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, May 21, 1940.

TO DISTRICT INSPECTORS OF
ELECTRICITY AND GAS.

Re: Approval New Type Overload
Bridge on Sangamo Types "CFA"
and "CFS" Watthour Meters

Dear Sirs:

This is to advise you that the National Research Council has approved a new type overload bridge for use on the Sangamo types "CFA" and "CFS" watthour meters. When this bridge is used, the type designations will become "CFA-1" and "CFS-1".

This is a magnetic bridge and is located between the poles of the series yoke, and helps to control the accuracy of the meter on overload.

Yours truly,



J. L. Stiver,
Director.

JLS/mee