

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, September 25, 1940.

TO DISTRICT INSPECTORS OF
ELECTRICITY AND GAS

Re: Approval of Sangamo Type "ED-30" Single-
phase Combination Demand Energy Meter
5-ampere Capacity

Dear Sirs;


This is to advise you that the type "ED-30" single-phase combination demand energy meter, manufactured by the Sangamo Company, Limited, Toronto, Canada, has been approved by the National Research Council for use in Canada in the following capacities:

Amperes: 5;
Voltages: 115, 230;
Frequency: 60 cycles;
Circuits: 2- and 3-wire.

The 3-wire meter is to be supplied with connecting links or their equivalent.

This is an extension of the approvals given for the use of the type "ED-30" combination meter in Circulars N.R.C. 125 and N.R.C. 129 to include the 5-ampere capacity meter.

Yours truly,



per H. A. Dupré,
Assistant Director.