

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, February 6, 1941.

TO DISTRICT INSPECTORS OF
ELECTRICITY AND GAS


Re: Approval of Canadian General Electric
Type "JE-1" and "JE-2" Potential
Transformers

Dear Sirs:

This is to advise you that the types "JE-1" and "JE-2" potential transformers, manufactured by the Canadian General Electric Company, Toronto, Canada, have been approved by the National Research Council for use in Canada in the following capacities:

Primary Voltage: 230, 460, 575, 2300, 2500;
Secondary Voltage: 115, or 125 for the 2500-volt
primary;
Volt-Ampere Rate: 200;
Frequency: 60 cycle.

Yours truly,



J. L. Stiver,
Director.