

Electricity

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, March 26, 1941.

TO DISTRICT INSPECTORS OF
ELECTRICITY AND GAS

Re: Sangamo Type "S-3" Single-phase
Watt-hour Meter with Low Glass
Cover.

Dear Sirs:


This is to advise you that the type "S-3" single-phase watt-hour meter, manufactured by the Sangamo Company, Limited, Toronto, Ontario, has been modified from the original meter, approved by N.R.C. 6, dated 25th September, 1930.

These modifications consist of a deeper pressed steel base, a shallower glass cover, the replacement of the adjusting screw for the light load attachment by a notched wheel, and a change in the terminals.

The meter element itself remains unchanged except for the terminals, which now are mounted in a bakelite block.

It has been determined by the National Research Council that the above changes are immaterial, and it will be in order for you to test and seal any type "S-3" meters embodying these changes.

Yours truly,



J. L. Stiver,
Director.

JLS/mee