

DEPARTMENT OF TRADE AND COMMERCE  
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, December 16, 1941.

TO DISTRICT INSPECTORS OF  
ELECTRICITY AND GAS

Re: Approval of Westinghouse type "CS-3"  
three-element detachable Watthour Meter.

Dear Sirs:

This is to advise you that the type "CS-3" three-element, detachable watthour meter, manufactured by the Canadian Westinghouse Company, Hamilton, Ontario, has been approved by the National Research Council for use in Canada in the following capacities:


| <u>Rated Current</u> | <u>Maximum Current</u> |
|----------------------|------------------------|
| 5                    | 15                     |
| 10                   | 30                     |
| 15                   | 45                     |
| 25                   | 60                     |
| 50                   | 90                     |

Voltage 115, 230, 460 and 575. The voltage marked may be changed to multiples of 120 without further approval.

The meter is approved for use on a frequency of 60 cycles only, and may be equipped with or without potential indicating lamps. Type "RW" and "RW-2" demand attachments may also be used.

The 5-ampere capacity may be furnished for use with current transformers and the 115-volt capacity for use with potential transformers.

Yours truly,



J. L. Stiver,  
Director.

JLS/mee