

File No.775

Electricity

DEPARTMENT OF TRADE AND COMMERCE  
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, January 21, 1942.

TO DISTRICT INSPECTORS OF  
ELECTRICITY AND GAS

Re: Alnico Magnets and Aluminum Lacquer  
for General Electric Watthour Meters

Dear Sirs:

This is to advise you that the National Research Council has approved the use of alnico magnets on General Electric watthour meters. The alnico magnet assembly is interchangeable with the chrome magnet assemblies on types "I-16", "I-20" and "I-30" single-phase watthour meters and all "V" type polyphase watthour meters.

Also, the National Research Council has approved the use of a grey enamel finish as a substitute for aluminum lacquer.

Yours truly,



J. L. Stiver,  
Director.

JLS/mee