

File No. 784

Electricity

DEPARTMENT OF TRADE AND COMMERCE  
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, January 21, 1942.

TO DISTRICT INSPECTORS OF  
ELECTRICITY AND GAS

Re: Approval of Changes in Cyclometer  
Registers and Permanent Magnets


Dear Sirs:

This is to advise you that the National Research Council has approved changes in cyclometer registers and permanent magnets manufactured by the Canadian Westinghouse Company, Hamilton, Ontario, as follows:

**CYCLOMETER REGISTERS:** The use of a new roller type of cyclometer register for use on all watt-hour meters which have been already approved for use with cyclometer registers. This register supersedes the jumper type of cyclometer register.

**PERMANENT MAGNETS:** The use of copper-plated permanent magnets in the types "CA", "CS" and "OC" watt-hour meters.

Yours truly,



J. L. Stiver,  
Director.

JLS/mee