

File No. 1126-3

N. R. C. 158

Electricity

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, October 27, 1943.

TO DISTRICT INSPECTORS OF
ELECTRICITY AND GAS

Re: Approval of Sangamo Auto Current
Transformers

Dear Sirs:

This is to advise you that the Sangamo Auto Current Transformer for use on 25 or 60 cycle circuits when connected in the secondaries of the main transformers for the purposes of giving a reading on a more desirable part of the scale of the recording or indicating meters has been approved by the National Research Council for use in Canada. This approval is not retroactive and applies only to transformers bearing Serial No. 24500 or higher. Due to space limitations, the information required by the specification may be shown on two name plates.

Yours truly,



J. L. Stiver,
Director.

JLS/mjm