

File C.C.E.-3

H.E.C. 151
Electricity

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, January 30, 1946

TO DISTRICT INSPECTORS OF
ELECTRICITY AND GAS


RE: Location seal pan on the socket
type meters

Dear Sirs:

This is to advise you that the National Research Council have notified the Canadian General Electric Company that they have approved the changing of the location of the seal pan on socket type meters from the present exposed position to the back of the meter, where it is protected from vandalism and weathering of the wax.

This approval will apply to the meters of other companies to whom the Canadian General Electric Company supply parts.

Yours truly,



J. H. Stiver,
Director.

JLS:bk