

File No. 756

M.R.C. 162  
Electricity

DEPARTMENT OF TRADE & COMMERCE  
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, January 30, 1946

TO DISTRICT INSPECTORS OF  
ELECTRICITY AND GAS.

Re: Approval of C.G.E. Type V-6A  
Watt-hour Meters

Dear Sirs:


This is to advise you that the type V-6A Watt-hour Meter manufactured by the General Electric Company and distributed in Canada by the Canadian General Electric Company in Toronto, has been approved by the National Research Council for use in Canada, provided the name plate or plates are marked to indicate the maximum current of the meter.

This approval covers the following capacities:  $2\frac{1}{2}$ , 5, 10, 15, 25 and 50 amperes, 230 volt, 60 cycles.

General Electric demand registers and other auxiliary devices such as demand contacts already approved, may be used on this meter.

Further, potential indicating lamps may be used on all General Electric meters.

Yours truly,



J. L. Stiver.