

File No. 1126-2

H.P.O. 267  
Electricity

DEPARTMENT OF TRADE AND COMMERCE  
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, 5 February, 1947

TO DISTRICT INSPECTORS OF  
ELECTRICITY & GAS


Re: Approval of Type "AAW" Packard,  
Current Transformer

Dear Sirs:

This is to advise you that the Type "AAW" Packard Current Transformer has been approved by the National Research Council for use in Canada.

This approval covers the use of the transformers on 25 to 60 cycle circuits, on power lines of not more than 240 volts and with burdens not more than 25 V.A. at 60 cycles and 15 V.A. at 25 cycles in 100-5, 150-5, 200-5 and 300-5 ranges.

Yours truly,



J. L. Stiver,  
Director.

JLS:bk