

File No. 725

F.R.C. 168
Electricity

DEPARTMENT OF TRADE AND COMMERCE
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, 10 February, 1947

TO DISTRICT INSPECTORS OF
ELECTRICITY AND GAS


Re: Approval Type REA Cyclometer
Register submitted by Canadian
General Electric Co.

Dear Sirs:

This is to advise you that the REA Type Cyclometer dial manufactured by the Canadian General Electric Company, Toronto, Ont., has been approved for use in Canada by the National Research Council.

Due to the intermittent motion of the lowest reading index a test dial is to be provided on all registers by uncovering the continuously moving drum on the right of the indices and marking it with ten equally spaced lines, one line being longer than the others.

Yours truly,



J. L. Stiver,
Director.

JLS:bk