

TRADE AND COMMERCE  
CANADA

## STANDARDS DIVISION

OTTAWA, May 1, 1948.

## MODIFICATION OF TYPE APPROVAL

The modification to the apparatus specified herein has been duly approved under the provisions of the appropriate Act, and the apparatus may be admitted to verification in Canada.

Authority:- The Electricity Inspection Act, Chapter 22, 1928.

Ruling Body:- The National Research Council.

Apparatus Modified:- Watthour meters A, A<sub>2</sub>A and A<sub>2</sub>S, manufactured by the Packard Electric Company, St. Catharines, Ontario.

Rating of Apparatus:- This modification will apply to all approved ratings.

Modification:- Relocation of the power factor compensating coil above the current coils instead of below, as located in the models originally approved.

Testing:- The above modification will not require any change in testing schedule, and the standard tests for 2- and 3-wire meters will apply.

L. V. Hunt,  
Chief Engineer

A. F. Gill,  
Director of Standards