



CANADA

DEPARTMENT OF TRADE AND COMMERCE
STANDARDS DIVISION

SD-FA.6

OTTAWA, May 16, 1950.
(Superseding Circular Letter SD-EC.26,
dated July 8, 1948)

MODIFICATION OF TYPE APPROVAL

The modification to the apparatus specified herein has been duly approved by the National Research Council under the provisions of The Electricity Inspection Act, Chapter 22, 1928, and the apparatus may be admitted to verification in Canada.

Apparatus Modified: Type "EDA" single-phase Combination Demand Energy Meter, manufactured by the Sangamo Company Limited, Leaside, Canada.

Rating of Apparatus:

Rated Amperes	50
Maximum Amperes	130
Voltages	115, 230, 460, 575
Wire	2 and 3
Frequency	25 and 60 cycles

Modification: The modification is simply an increase of the maximum capacity of the 50-ampere "EDA" Sangamo combination meter from 100 to 130 amperes.

E. F. Power,
Assistant Director (E.&G.),
Standards Division.

R. W. Maclean,
Director,
Standards Division.