



CANADA

SD.EA.8

DEPARTMENT OF TRADE AND COMMERCE
STANDARDS DIVISION

OTTAWA, May 16, 1950.
(Superseding Circular Letter SD.EC.28,
dated July 23, 1948)

NOTIFICATION OF TYPE APPROVAL

The apparatus specified herein has been duly approved by the National Research Council under the provisions of The Electricity Inspection Act, Chapter 22, 1928, and may be admitted to verification in Canada.

Apparatus Approved: Types "S3A" and "S3S" single-phase Watthour Meters, manufactured by the Sangamo Company Limited, Leaside, Canada.

Rating of Apparatus:

Rated Amperes	All ratings up to 50 amperes
Maximum Amperes ...	Three times rated except limited to 130 amperes in the "A" base and 100 amperes in the "S" base
Voltages	115, 230, 460, 575
Wire	2 and 3
Frequency	25 and 60 cycles
Registers	Cyclometer or clock registers or approved demand attachments.

Description: These meters consist of the regular "S3" type element, mounted in the "A" or "S" bases. In order to adapt the "S3" parts to these bases, it was necessary to provide only a modified grid, combining, in this new member, mounting holes to match the "A" and "S" bases, and make provision for attaching to it the "S3" parts.

R. W. MacLean,
Director,
Standards Division.

E. F. Power,
Assistant Director (E. & G.),
Standards Division.