



CANADA

DEPARTMENT OF TRADE AND COMMERCE
STANDARDS DIVISION

SD-EA.33

OTTAWA.....July 11, 1950.....

MODIFICATION OF TYPE APPROVAL

The modification to the apparatus specified herein has been duly approved by the Standards Division under the provisions of The Electricity Inspection Act, Chapter 22, 1928, and the apparatus may be admitted to verification in Canada.

Apparatus Modified: Types "CA" and "CS" Single-Phase Watthour Meters and all approved types of "CA" and "CS" Polyphase Meters, manufactured by the Canadian Westinghouse Company, Limited, Hamilton, Ontario.

Rating of Apparatus: All approved ratings of the above-named types of meters.

Modification: The modification consists of using cable with plastic insulation, instead of rubber or other insulation, for the current coils of these meters and the change is considered an immaterial alteration.

E. F. Power,
Assistant Director (E. & G.),
Standards Division.

R. W. MacLean,
Director,
Standards Division.