



CANADA

DEPARTMENT OF TRADE AND COMMERCE  
STANDARDS DIVISION

OTTAWA, December 14, 1950.

## MODIFICATION OF TYPE APPROVAL

The modification to the apparatus specified herein has been duly approved by the Standards Division under the provisions of The Electricity Inspection Act, Chapter 22, 1928, as amended, and the modified apparatus may be admitted to verification in Canada.

Apparatus Modified: Types "A", "A1", "A2", "A1A", "A2A", "A1S" and "A2S" Single-Phase Watthour Meters, manufactured by the Packard Electric Company, Limited, St. Catharines, Ontario.

Rating of Apparatus: All approved ratings of the above-named types of meters.

Modification: The modification consists of the use of a new lower bearing cartridge assembly complete with jewel, to replace the former two-piece assembly used. The new assembly is interchangeable with the old assembly, and can be used on new meters as well as a replacement for the older meters as mentioned above. The new assembly uses aluminum in place of steel, as formerly used.

E. F. Power,  
Assistant Director, (E. & G.),  
Standards Division.

R. W. MacLean,  
Director,  
Standards Division.