



CANADA

DEPARTMENT OF TRADE AND COMMERCE  
STANDARDS DIVISION

OTTAWA, January 3, 1951.

## MODIFICATION OF TYPE APPROVAL

The modification to the apparatus specified herein has been duly approved by the Standards Division under the provisions of The Electricity Inspection Act, Chapter 22, 1928, as amended, and the modified apparatus may be admitted to verification in Canada.

Apparatus Modified: Type "CS-1" and Type "CA" Single-Phase Watt-hour Meters (except the 50-ampere type "CS-1" watt-hour meter with the special high-capacity base and terminals -- see Approval Circular SD-EA.23), manufactured by the Canadian Westinghouse Company Limited, Hamilton, Ontario.


Original approval of type was given to these meters under Circular NRC-143.


Rating of Apparatus: All approved capacities of the above-named types of meters.

Modification: The modification consists of the addition of maximum ratings to nameplates of these meters according to the following schedule:

<u>Rated Amps.</u>	<u>Maximum Amps.</u>
2.5	10
5	20
10	40
* 15	60
25	100
50	100

\* Note: Approval for the 15-ampere capacity was previously granted on August 12, 1947, under Circular NRC-169.

  
R. W. MacLean,  
Director,  
Standards Division.



E. F. Power,  
Assistant Director, (E&G),  
Standards Division.