



CANADA

DEPARTMENT OF TRADE AND COMMERCE
STANDARDS DIVISION

OTTAWA, March 5, 1951.

NOTIFICATION OF TYPE APPROVAL

The apparatus specified herein has been duly approved by the Standards Division under the provisions of The Electricity Inspection Act, Chapter 22, 1928, as amended, and may be admitted to verification in Canada.

Apparatus Approved: Type "MV" 6900-volt Metering Outfit, manufactured by the Packard Electric Company, Limited, St. Catharines, Ontario.

Rating of Apparatus:

Volts 6900
Cycles 60
Phase 1
Wire 2
Meter Size 5 to 50 amp.
Meter Volts 115
Burden 10 VA.

Description: The unit consists of an auto-transformer, rated at 6900/115 volts, and a single-phase watthour or demand meter, all housed in a weather-proof metal case with hinged front cover and glass window. It is designed for outdoor mounting on a pole line and connection to a 6900-volt supply. The output, also at 6900 volts, is then available for rural lines or small industries. The housing is connected to ground at the top mounting stud. This unit is similar, except for the auto-transformer, to the outfits approved under Circulars SD-EA.45 and SD-EA.52 of November 28, 1950, and February 20, 1951, respectively.

Limitation of Approval: Approved for use with any approved meter imposing a burden of not more than 10 VA.

E. F. Power,
Assistant Director, (E&G),
Standards Division.

R. W. Maclean,
Director,
Standards Division.