



CANADA

DEPARTMENT OF TRADE AND COMMERCE
STANDARDS DIVISION

OTTAWA, March 7, 1951.
(Apparatus approved
July 25, 1949)

NOTIFICATION OF TYPE APPROVAL

The apparatus specified and illustrated herein has been duly approved by the Standards Division under the provisions of The Electricity Inspection Act, Chapter 22, 1928, and may be admitted to verification in Canada.

Apparatus Approved: Type "P" polyphase Watthour Meter, manufactured by Smith Meters Limited, London, England.

Rating of Apparatus:

Amperes 10
Volts 220
Frequency 60 cycles
Wire 3
Phase 2 or 3

Description: This meter is of the ordinary bottom connected style (not A-base) with standard terminal connections. It has a metal base and cover with large window. The diagram of connections is pasted in the cover plate.

Conditions: Approval covers meters fitted with cyclometer registers but not those fitted with clock-type registers.

E. F. Power

E. F. Power,
Assistant Director, (E&G),
Standards Division.

R. W. MacLean
R. W. MacLean,
Director,
Standards Division.

SMITH METERS LIMITED TYPE "F" FOLIOGRAPH WATERMETER
(Cover and Register Removed)

