



CANADA

DEPARTMENT OF TRADE AND COMMERCE
STANDARDS DIVISION

OTTAWA, May 28, 1951.

NOTIFICATION OF TYPE APPROVAL

The apparatus specified and illustrated herein has been duly approved by the Standards Division under the provisions of The Electricity Inspection Act, Chapter 22, 1928, as amended, and may be admitted to verification in Canada.

Apparatus Approved: Form #Q3C Cyclometer Register, manufactured by the Canadian General Electric Company, Limited, Toronto, Ontario, for use on all approved Canadian General Electric watt-hour meters.

Description: The movement consists of five cylinders, with numbers on the circumference, mounted on a rigid die cast base. The motion is transmitted from one cylinder to the next through interlocking gears. The figures on the cylinders are viewed through square windows in the register face but the right hand dial is blanked out, i.e., there is no corresponding window in the register face. There is a small test dial of the clock type placed in line with, and to the right of, the main dial windows.


E. F. Power,
Assistant Director, (E&G),
Standards Division.

R. W. MacLean,
Director,
Standards Division.

Ref: A-188

CANADIAN GENERAL ELECTRIC FORM #Q3C CYCLOMETER REGISTER

(Front View)



(Rear View)

