



CANADA

DEPARTMENT OF TRADE AND COMMERCE  
STANDARDS DIVISION

SD-BA.66

OTTAWA, August 20, 1951.


MODIFICATION OF TYPE APPROVAL

The modification to the apparatus specified and illustrated herein has been duly approved by the Standards Division under the provisions of The Electricity Inspection Act, Chapter 22, 1928, as amended, and the modified apparatus may be admitted to verification in Canada.

Apparatus Modified: Types "EDA" and "EDS" Combination Single-Phase Watthour and Demand Meters, manufactured by the Sangamo Company Limited, Leaside, Ontario.

Rating of Apparatus: All approved ratings of the above-named types of meters.

Modification: The modification consists of completely enclosing the thermal element in a metal frame. The object of using the complete enclosure, instead of the open frame formerly used, is to provide thermal shielding. The shielding is important where the meter is to be located outdoors or in direct sunlight.

  
R. W. Maclean,  
Director,  
Standards Division.



E. F. Power,  
Assistant Director (E&G),  
Standards Division.

Ref: A-223

THERMAL ELEMENT AND SHIELDING  
FOR  
SANGAMO TYPES "EDA" AND "EDS"  
COMBINATION WATERFLOU AND DEMAND METERS

