



CANADA

DEPARTMENT OF TRADE AND COMMERCE
STANDARDS DIVISION

OTTAWA, September 13, 1951.

MODIFICATION OF TYPE APPROVAL

The modification to the apparatus specified herein has been duly approved by the Standards Division under the provisions of The Electricity Inspection Act, Chapter 22, 1928, as amended, and the modified apparatus may be admitted to verification in Canada.

Apparatus Modified: Types "ALSW" and "ALAW" Single-Phase Three-Wire Watthour Meters for use on 60 cycles, manufactured by the Packard Electric Company Limited, St. Catharines, Ontario.

Rating of Apparatus:

Rated Amperes	25
Voltage	115/230
Wire	3
Phase	1
Frequency	60 cycles
Watthour Constant (K _h)	3.333

Description: These meters are the 60-cycle version of the types approved under Circular SD-EA.35, dated August 14, 1950. They are essentially the same as the types "ALS" and "ALA" except for different gearing in the register and calibration to the different constant.

Additional Approval: Under this approval, the Packard Electric Company Limited has permission to convert any existing types "ALS" and "ALA" meters of the above rating to this new type and speed by changing the gears in the register, re-calibrating, and providing a new nameplate which shall show the new type designation, new watthour constant, and have an "X" after the serial number.

R. W. MacLean
R. W. MacLean,
Director,
Standards Division.

J. R. Gardiner
for
E. F. Power,
Assistant Director (F&G),
Standards Division.

Ref: A-171A