

TRADE AND COMMERCE
CANADA

STANDARDS DIVISION

OTTAWA, September 8, 1953.

TYPE APPROVALCANADIAN GENERAL ELECTRIC
TYPES "WF1B" AND "WF2B" CURRENT TRANSFORMERS

The apparatus specified herein has been duly approved by the Standards Division under the provisions of The Electricity Inspection Act, Chapter 22, 1928, as amended, and may be admitted to verification in Canada.

Apparatus Approved: Types "WF1B" and "WF2B" Current Transformers, manufactured by the Canadian General Electric Company Limited, Toronto, Ontario.

Rating of Apparatus:

Primary Current 5, 10, 15, 20, 25, 30, 40, 50, 60, 80,
100, 125, 150, 200, 250, 300, 400, 500,
600, 800 amperes

Secondary Current 5 amperes

Rated Metering Burden 12.5 VA at 0.9 P.F. (ASA 0.3B0.5)

Rated Voltage 5 KV (WF1B); 7.5 KV (WF2B)

Wire 2

Phase 1

Frequency 25/60 cycles

Style Dry Indoor.

Description: The types "WF1B" and "WF2B" current transformers supersede the types "WF1A" and "WF2A" respectively, approved under Circular SD-EA.88 of October 28, 1952. Certain mechanical changes have been made which alter the appearance of the former types slightly but which in no way affect the electrical characteristics of the transformers.

The types "WF1B" and "WF2B" are similar except for the voltage rating.

E. F. Power,
Assistant Director (E&G),
Standards Division.

R. W. MacLean,
Director,
Standards Division.