



TRADE AND COMMERCE
CANADA

STANDARDS DIVISION

OTTAWA..... April 5, 1954.

TYPE APPROVALSANGAMO TYPES "NBS" AND "NBAP" POLYPHASE WATTHOUR METERS

The apparatus specified and illustrated herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Types "NBS" and "NBAP" 2-Element Polyphase Watt-hour Meters, manufactured by the Sangamo Company Limited, Leaside, Toronto 17, Canada.

Rating of Apparatus:

Nominal Amperes	2.5, 5, 10, 15, 50 *
Maximum Amperes	10, 20, 40, 60, 100
Voltages	115, 230, 460, 575
Wire	3
Elements	2
Frequency	60 cycles.

* 25-ampere meters given approval previously on Circular SD-EA.133 of December 11, 1953.

Description: These meters are to the same design as those described and approved under Circular SD-EA.133.

E. F. Power,
Assistant Director (E&G),
Standards Division.

R. W. MacLean,
Director,
Standards Division.

Ref: A-337B&C

SD-EA.147

SANGAMO TYPE "NBS" 2-ELEMENT POLYPHASE WATTHOUR METER

