



TRADE AND COMMERCE  
CANADA

## STANDARDS DIVISION

OTTAWA..... April 22, 1954...

TYPE APPROVALCANADIAN WESTINGHOUSE TYPES "CAH" AND "CSH" DEMAND-ENERGY METERS

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R. S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Types "CAH" and "CSH" Single-Phase Demand-Energy Meters, manufactured by the Canadian Westinghouse Company Limited, Hamilton, Ontario.

## Rating of Apparatus:

Nominal Amperes .....	2.5
Maximum Amperes .....	8-1/3
Volts .....	120
Wire .....	2
Full Scale Demand (KW) .....	1
Kh .....	1/6
Test Period .....	32 minutes
Phase .....	1
Frequency .....	60 cycles

Description: These meters are similar in general design and performance to those of the same type approved under Circular SD-EA.141 of February 15, 1954.

E. F. Power,  
Assistant Director (E&G),  
Standards Division.

R. W. MacLean,  
Director,  
Standards Division.

Ref: A-157D