



TRADE AND COMMERCE  
CANADA

SD-EA.167

## STANDARDS DIVISION

OTTAWA, November 22, 1954.

TYPE APPROVALSANGAMO TYPES "CFA" AND "CFS" SINGLE-PHASE WATTHOUR METERS

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Types "CFA" and "CFS" Single-Phase Watthour Meters, manufactured by the Sangamo Company Limited, Leaside, Toronto 17, Ontario.

## Rating of Apparatus:

Nominal Amperes ..... 2.5, 5, 10, 15, 25, 50  
Volts ..... 120, 240  
Wire ..... 2, 3, 2/3 (in 15 and 25 amperes)  
Frequency ..... 25, 60 cycles.

Note: For maximum amperes and other details, see Circular SD-EA.134 of December 11, 1953.

Description: This approval permits 120, 240 volt ratings for all 60-cycle "CFA" and "CFS" meters including conversion type for use temporarily on 25 cycles. In all other respects the meters are exactly the same as those approved under earlier circulars (see SD-EA.134). Nameplates of the types "CFA" and "CFS" meters may now be marked with either the 115, 230 volt ratings or the 120, 240 volt ratings.

E. F. Power,  
Assistant Director (E&G),  
Standards Division.

R. W. MacLean,  
Director,  
Standards Division.

Ref: A-411