

SD-EC 169
S. D. E. C. 169

DEPARTMENT OF TRADE & COMMERCE
STANDARDS DIVISION

File No. 784

OTTAWA, August 12th, 1947

TO DISTRICT INSPECTORS
OF ELECTRICITY & GAS


Re: Type CA and CS Single Phase
Meter Nameplates

Dear Sirs:

The Canadian Westinghouse Company, Limited, has asked permission to alter the nameplates of their type CA and CS single phase watt-hour meter to include a maximum ampere rating of 60 for the 15 ampere, 115/230 volt, 3 wire watt-hour meter.

This is to advise that the National Research Council has approved this change.

Yours truly,



J. L. Stiver,
Assistant Director of Standards.

JLS:bk