

SD-EC-171

DEPARTMENT OF TRADE & COMMERCE  
STANDARDS DIVISION

File No: S.837

OTTAWA, Ont., 12th Sept. 1947.

TO DISTRICT INSPECTORS  
OF ELECTRICITY & GAS

Re: Change of Mounting Posts on  
Type C.S. detachable Meters  
From Brass With Nickel Plat-  
ing to Aluminum.

Dear Sirs:

The Canadian Westinghouse Company have applied to the National Research Council for permission to change the mounting posts on the Type C.S. detachable watt-hour meters from Brass with nickel plating to Aluminum. This change has been approved by the National Research Council and it may be made at the convenience of the Company.

Yours faithfully,



J.L. Silver,  
Assistant Director of Standards.

JLS:WT