


 TRADE AND COMMERCE
 CANADA

SD-EA.181

STANDARDS DIVISION

OTTAWA, March 15, 1955.

TYPE APPROVAL
 VARIOUS TYPES OF SANGAMO SINGLE-PHASE AND POLYPHASE
 DEMAND AND COMBINATION METERS, AS GIVEN BELOW
 (For Nameplate Markings of 120 Volts and Multiples Thereof)


The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R. S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Types "WD-2", "WD-3", "WDA", "WDS", "VA-3", "SC Graphic", "CCW", "CCVA", "WD-3 Duplex", "EDA", "EDS", "AEA" and "AES" Single-Phase and Polyphase Demand and Combination Meters, manufactured by the Sangamo Company Limited, Leaside, Toronto 17, Ontario.

Rating of Apparatus: As previously approved except for the voltage rating. See the following Approval Circulars:-

Meter Type	Single-phase or Polyphase	Approval Number
"WD-2"	Polyphase	NRC-11
"WD-3"	Polyphase	NRC-46, NRC-49
"WDA" and "WDS"	Single-phase	SD-EA.4
"VA-3"	Polyphase	NRC-51, NRC-52
"SC Graphic"	Polyphase	NRC-18, NRC-29, NRC-95, NRC-130, SD-EA.90
"CCW"	Polyphase	NRC-74
"CCVA"	Polyphase	NRC-81
"WD-3 Duplex"	Polyphase	NRC-131, SD-EA.77
"EDA" and "EDS"	Single-phase	NRC-166, SD-EA.5, SD-EA.6, SD-EA.24, SD-EA.66, SD-EA.76
"AEA" and "AES"	Single-phase	SD-EA.64

Description: These meters are identical to the same types approved under previous circulars (as above) except that the manufacturer is permitted to mark the nameplates with either 120-volt ratings and multiples thereof or the former 115 volts and multiples.


 R. W. MacLean,
 Director,
 Standards Division.

Ref: A-424A


 E. F. Power,
 Assistant Director (E&G),
 Standards Division.

