

TRADE AND COMMERCE  
CANADASD-EA.185-A  
(Supplementary to  
SD-EA.185)

## STANDARDS DIVISION

OTTAWA, September 19, 1955.

TYPE APPROVALCANADIAN GENERAL ELECTRIC  
TYPES "CM-5" AND "CM-8.7" CURRENT TRANSFORMERS

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Types "CM-5" and "CM-8.7" Current Transformers, manufactured by the Canadian General Electric Company Limited, Toronto, Ontario.


## Rating of Apparatus:


Primary Current .....	5, 10, 15, 20, 25, 30, 40, 50, 60, 75, 80, 100, 125, 150, 200, 250, 300, 400, 500, 600, 800 amperes
Secondary Current .....	5 amperes
Accuracy Class .....	ASA 0.3B0.1, 0.3B0.5 <sup>*</sup> , 0.3B2.0
Rated Voltage .....	5 KV (CM-5); 8.7 KV (CM-8.7)
Wire .....	2
Phase .....	1
Frequency .....	25-60 cycles
Style .....	Dry Indoor

\* marked on nameplate.

Description: The manufacturer has asked, and his request has been granted, that Approval Circular SD-EA.185 of April 20, 1955 be amended in two instances, as follows: (1) the "Accuracy Class" ASA 0.3B2.0 be changed to ASA 0.3B0.1, 0.3B0.5, 0.3B2.0, with ASA 0.3B0.5 shown on the nameplate, and (2) the "Rated Voltage" of the type "CM-8.7" be changed from 7.5 KV to 8.7 KV. The performance and general construction of the transformers approved in SD-EA.185 have not been altered.

This circular should be attached to SD-EA.185.

  
R. W. MacLean,  
Director,  
Standards Division.

  
E. F. Power,  
Assistant Director (ESG),  
Standards Division.

