

TRADE AND COMMERCE  
CANADA

## STANDARDS DIVISION

OTTAWA, June 15, 1955.

TYPE APPROVALPACKARD TYPE "E2.5" CURRENT TRANSFORMER

The apparatus specified and illustrated herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "E2.5" Current Transformer, manufactured by the Packard Electric Company Limited, St. Catharines, Ontario.

## Rating of Apparatus:

Primary Current ..... 10 amperes  
Secondary Current ..... 5 amperes  
Voltage Rating ..... 2.5 KV  
Accuracy Rating - at 60 cycles ... 0.3B0.1, 0.3B0.5<sup>\*</sup>, 0.3B0.9, 0.6B2.0  
- at 25 cycles ... 0.6B0.1, 0.6B0.5, 0.6B0.9, 0.6B2.0  
Frequency ..... 25 - 60 cycles  
Style ..... Dry Indoor


<sup>\*</sup> shown on nameplate.

Description: These transformers are intended for indoor service. Polarity is indicated by red paint dots on the insulation near one primary terminal and near the corresponding secondary terminal. Short-circuiting of the secondary is effected by means of a screw-fastened link.

E. F. Power,  
Assistant Director (E&G),  
Standards Division.

R. W. Maclean,  
Director,  
Standards Division.

Ref: A-458



PACKARD TYPE "E2.5" CURRENT TRANSFORMER

