



TRADE AND COMMERCE
CANADA

SD-EA.201

STANDARDS DIVISION

OTTAWA, June 30, 1955.

TYPE APPROVALPACKARD TYPE "VL1" VOLTAGE TRANSFORMER

The apparatus specified and illustrated herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "VL1" Voltage Transformer, manufactured by the Packard Electric Company Limited, St. Catharines, Ontario.

Rating of Apparatus:


Primary Voltage	230, 275, 345, 460, 575
Secondary Voltage	115, 110, 115, 115, 115
Accuracy Rating	ASA 1.2 W
Insulation Class	600 volts
Frequency	60 cycles
Style	Dry Indoor.

Description: The type "VL1" is a small indoor voltage transformer. Polarity is indicated by the colour of the leads. The leads of both primary and secondary are #12 Flex Flameseal coloured red or black. The primary and secondary are distinguished by the voltage stencilled in white adjacent to the appropriate leads.

E. F. Power,
Assistant Director (E&G),
Standards Division.

R. W. MacLean,
Director,
Standards Division.

Ref: A-434



PACKARD TYPE "VL1" VOLTAGE TRANSFORMER

