

TRADE AND COMMERCE  
CANADA

SD-EA.202

## STANDARDS DIVISION

OTTAWA, July 5, 1955.

TYPE APPROVALSANGAMO TYPES "CF2A" AND "CF2S" SINGLE-PHASE WATTHOUR METERS

The apparatus specified and illustrated herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Types "CF2A" and "CF2S" Single-Phase Watthour Meters, manufactured by the Sangamo Company Limited, Leaside, Toronto 17, Ontario.


## Rating of Apparatus:

Normal Range .....	0.75-100 amperes;	2.0-200 amperes*
Voltage .....	230 or 240	230 or 240
Wire .....	3	3
Frequency .....	60 cycles	60 cycles
K <sub>h</sub> .....	3-1/3	6-2/3

\* with "S"-type base only.

Description: The Sangamo types "CF2A" and "CF2S" are similar in general construction to the already-approved types "CFA" and "CFS" respectively.

Approval includes use of the meters with either clock or cyclometer registers. It should be noted that the 0.75-100 ampere range registers must incorporate a test dial whereas the 2.0-200 ampere range registers need not do so. Registers for the latter capacity meter are four-dial with multiplier of ten.

  
R. W. MacLean,  
Director,  
Standards Division.

  
E. F. Power,  
Assistant Director (E&G),  
Standards Division.

Ref: A-461

1

2

3

SANGAMO TYPE "CF2A" SINGLE-PHASE WATTHOUR METER

