

TRADE AND COMMERCE  
CANADA

SD-EA.209

## STANDARDS DIVISION

OTTAWA, September 9, 1957.

MODIFICATION OF TYPE APPROVALCANADIAN GENERAL ELECTRIC  
TYPES "I-55A" AND "I-55S" WATTHOUR METERS

The modifications to the apparatus specified herein have been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and the modified apparatus may be admitted to verification in Canada.

Apparatus Modified: Types "I-55A" and "I-55S" Single-Phase Watthour Meters, manufactured by the Canadian General Electric Company Limited, Quebec 8, P. Q.

## Rating of Apparatus:

Normal Range ..... 0.75 - 100 amperes  
Voltage ..... 230 or 240  
Wire ..... 3  
Frequency ..... 60 cycles  
K<sub>h</sub> ..... 3.6

## Modifications: The modifications approved herewith are two in number:

In the first, the overload compensation is altered by changing the number, thickness and arrangement of the compensating shunts and spacers on the current laminations. In the second, which applies only to the type "I-55S", a rubber gasket replaces the cork gasket formerly used.

E. F. Power,  
Assistant Director (E&G),  
Standards Division.

R. W. MacLean,  
Director,  
Standards Division.

Ref: A-486

