


 TRADE AND COMMERCE
CANADA

STANDARDS DIVISION

OTTAWA, November 15, 1955.

TYPE APPROVALPACKARD TYPE "E2.5" CURRENT TRANSFORMER

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "E2.5" Current Transformer, manufactured by the Packard Electric Company Limited, St. Catharines, Ontario.

Rating of Apparatus:

Primary Current	5 amperes
Secondary Current	5 amperes
Voltage Rating	2.5 KV
Accuracy Rating - at 60 cycles	0.3B0.1, 0.3B0.5 [*] , 0.3B0.9, 0.6B2.0
- at 25 cycles	0.6B0.1, 0.6B0.5, 0.6B0.9, 0.6B2.0
Frequency	25-60 cycles
Style	Dry Indoor

^{*} shown on nameplate.

Description: These transformers in the 5-5 ratio are identical in design to the 10-ampere and 20-ampere ratings approved on June 15, 1955 and August 2, 1955 respectively. (See Circulars SD-EA.195 and SD-EA.203.)

E. F. Power,
Assistant Director (E&G),
Standards Division.

R. W. MacLean,
Director,
Standards Division.

Ref: A-458A

