



TRADE AND COMMERCE  
CANADA

SD-EA.229

## STANDARDS DIVISION

OTTAWA, February 1, 1956.

TYPE APPROVALPACKARD TYPE "E2.5" CURRENT TRANSFORMER

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "E2.5" Current Transformer, manufactured by the Packard Electric Company Limited, St. Catharines, Ontario.

## Rating of Apparatus:

Primary Current .....	5, 10, 15, 20, 25, 40, 50, 75, 100, 150, 200, 300, 400, 500, 600 amperes
Secondary Current .....	5 amperes
Voltage Rating .....	2.5 KV
Accuracy Rating - at 60 cycles ....	0.3B0.1, 0.3B0.5 <sup>*</sup> , 0.3B0.9, 0.6B2.0
- at 25 cycles ....	0.6B0.1, 0.6B0.5, 0.6B0.9, 0.6B2.0
Frequency .....	25-60 cycles
Style .....	Dry Indoor

<sup>\*</sup> shown on nameplate.

Description: These transformers are identical in design to the 5-ampere, 10-ampere, and 20-ampere ratings approved respectively under  
SD-EA.195, June 15, 1955  
SD-EA.203, August 2, 1955  
SD-EA.220, November 15, 1955.

The ratings formerly approved have been included in the list above so as to show all sizes approved to date on this one circular.

E. F. Power,  
Assistant Director (E&G),  
Standards Division.

R. W. MacLean,  
Director,  
Standards Division.

Ref: A-458C

1

2

3