



TRADE AND COMMERCE
CANADA

STANDARDS DIVISION

OTTAWA, February 17, 1956.

TYPE APPROVAL

ENGLISH ELECTRIC TYPES "KSA-5", "KSA-8" AND "KSA-15"
CURRENT TRANSFORMERS

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Types "KSA-5", "KSA-8" and "KSA-15" Current Transformers, manufactured by the English Electric Company of Canada Limited, St. Catharines, Ontario.

Rating of Apparatus:

Primary Current 5, 10, 15, 20, 25, 30, 40, 50, 75, 100, 125,
150, 200, 250, 300, 400, 500, 600, 800 amperes
Secondary Current 5 amperes
Metering Burden* 50 VA, 0.5 p.f.
Accuracy Rating* ASA 0.3B0.1, 0.3B0.5, 0.6B2.0 on 25 and 60 cycles
Rated Voltage 5 KV, 8.7 KV and 15 KV
Wire 2
Frequency 25 and 60 cycles
Style Dry Indoor

* Either the Metering Burden or the Accuracy Rating shall be stamped on the nameplate. It is permissible to stamp both if required.

Description: These transformers are identical with those of the same type designation covered in Approval Circular SD-EA.104 of April 24, 1953. The purpose of this circular is to delineate the accuracy rating for the type since this was not done in the original approval.

E. F. Power,
Assistant Director (E&G),
Standards Division.

R. W. MacLean,
Director,
Standards Division.

Ref: A-520A

