



TRADE AND COMMERCE  
CANADA

## STANDARDS DIVISION

OTTAWA.....March 22, 1956.

TYPE APPROVALSANGAMO TYPES "CF2A" and "CF2S" 2-WIRE/3-WIRE WATTHOUR METERS

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Types "CF2A" and "CF2S" 2-wire/3-wire single-phase watt-hour meters, manufactured by the Sangamo Company Limited, Leaside, Toronto 17, Ontario.

## Rating of Apparatus:

As 2-wire meter


Type ..... CFA or CFS  
Nominal Amperes ..... 25  
Maximum Amperes ..... 100  
Voltage ..... 115 or 120  
Frequency ..... 60 cycles  
Kh ..... 3-1/3

As 3-wire meter

Type ..... CF2A or CF2S  
Normal Range ..... 0.75 - 100 amperes  
Voltage ..... 230 or 240  
Frequency ..... 60 cycles  
Kh ..... 3-1/3

Description: Under Approval Circular SD-EA.67, August 31, 1951, approval was granted to the Sangamo Type CFA and CFS convertible 2-wire/3-wire meter. Since the type CF2A and CF2S are exactly the same as the most recent modifications of the types CFA and CFS except for the nameplate, approval is hereby granted for the convertible 2-wire meter type CFA or CFS to become a 3-wire meter type CF2A or CF2S. In other words, two nameplates will be provided on the meter--one on top of the other. The top nameplate will indicate that the meter is a type CFA or CFS 2-wire meter. This nameplate will be discarded when the meter is changed to 3-wire and the second nameplate will then indicate that the meter is a type CF2A or CF2S 3-wire meter.

This approval covers the 25 ampere nominal, 60-cycle meter only.

  
R. W. MacLean,  
Director,  
Standards Division.

  
E. F. Power,  
Assistant Director (E&G),  
Standards Division.

