

TRADE AND COMMERCE  
CANADA

## STANDARDS DIVISION

OTTAWA, May 8, 1956.

TYPE APPROVALPACKARD TYPE "E2.5" CURRENT TRANSFORMER

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "E2.5" Current Transformer, manufactured by the Packard Electric Company Limited, St. Catharines, Ontario.

## Rating of Apparatus:

Primary Current .....	125 amperes
Secondary Current .....	5 amperes
Voltage Rating .....	2.5 kV
Accuracy Rating - at 60 cycles ....	0.3B0.1, 0.3B0.5 <sup>*</sup> , 0.3B0.9, 0.6B2.0
- at 25 cycles ....	0.6B0.1, 0.6B0.5, 0.6B0.9, 0.6B2.0
Frequency .....	25-60 cycles
Style .....	Dry Indoor

<sup>\*</sup> shown on nameplate.

Description: The type "E2.5" current transformer in various primary ratings from 5 to 600 amperes was approved under Circular SD-EA.229 of Feb. 1, 1956. This range of ratings is now extended to include the 125-5 ampere rating approved herein.

E. F. Power,  
Assistant Director (E&G),  
Standards Division.

R. W. Maclean,  
Director,  
Standards Division.

Ref: A-458C

1

2

3