

TRADE AND COMMERCE
CANADA

SD-EA.246

STANDARDS DIVISION

OTTAWA, May 29, 1956.

TYPE APPROVALPACKARD TYPES "E-5" AND "E-15" CURRENT TRANSFORMERS

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Types "E-5" and "E-15" Current Transformers, manufactured by the Packard Electric Company Limited, St. Catharines, Ontario.

Rating of Apparatus:

Primary Current 60 amperes
 Secondary Current 5 amperes
 Voltage Rating 5 KV and 15 KV
 Accuracy Rating 0.3B0.5
 Frequency 25 - 60 cycles
 Style Dry Indoor

Description: These transformers are identical in design to the current transformers (Types "E-5" and "E-15") approved under SD-EA.106 of May 13, 1953. The rating approved herein is, therefore, to be included with the ratings previously approved.

E. F. Power,
 Assistant Director (E&G),
 Standards Division.

R. W. MacLean,
 Director,
 Standards Division.

