



STANDARDS DIVISION

OTTAWA, June 25, 1956.

MODIFICATION OF TYPE APPROVALPACKARD CURRENT TRANSFORMERS,
TYPES "A", "BH", "BV", "BR", "G", "GC", "RT" AND "RF"

The modifications to the apparatus specified herein have been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and the modified apparatus may be admitted to verification in Canada.

Apparatus Modified: Types "A", "BH", "BV", "BR", "G", "GC", "RT" and "RF"
Current Transformers, manufactured by the Packard Electric Company Limited,
St. Catharines, Ontario.

Rating of Apparatus: See Circular NRC-72, dated June 20, 1935.

Modification: Circular NRC-72 of June 20, 1935 included approval of the above-mentioned types of current transformers in a design for use on 7000-volt service. The transformers were designated "A7", "BH7" etc. Circular SD-EA.102 of April 1, 1953 extended the approval granted under NRC-72 to include the above types with suffixes "7.5" and "8". This present approval now extends the original approval to include the suffix "8.7". There is no change in the electrical characteristics or design of the transformers.

E. F. Power,
Assistant Director (E&G),
Standards Division.

R. W. MacLean,
Director,
Standards Division.

