



TRADE AND COMMERCE
CANADA

SD-EA.260

STANDARDS DIVISION

OTTAWA, August 23, 1956.

TYPE APPROVALPACKARD TYPE "E2.5" CURRENT TRANSFORMER

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "E2.5" Current Transformer, manufactured by the Packard Electric Company Limited, St. Catharines, Ontario.

Rating of Apparatus:

Primary Current 6 amperes
 Secondary Current 5 amperes
 Voltage Rating 2.5 KV
 Accuracy Rating 0.3B0.1, 0.3B0.5*, 0.3B0.9, 0.6B2.0
 Frequency 60 cycles
 Style Dry Indoor

* shown on nameplate.

Description: These transformers in the 6-5 ratio are essentially the same in design and appearance as the 5-ampere, 10-ampere, and 20-ampere ratings approved respectively on November 15, 1955, June 15, 1955 and August 2, 1955. (See Circulars SD-EA.220, SD-EA.195 and SD-EA.203).

E. F. Power

E. F. Power,
 Assistant Director (E&G),
 Standards Division.

R. W. MacLean
 R. W. MacLean,
 Director,
 Standards Division.

Ref: A-524

1

2

3