

TRADE AND COMMERCE  
CANADA

## STANDARDS DIVISION

OTTAWA, October 15, 1956.

TYPE APPROVALCANADIAN WESTINGHOUSE CYCLOMETER REGISTERS  
FOR TYPES "DA" AND "DS" WATTHOUR METERS

The apparatus specified and illustrated herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Cyclometer Registers for use with types "DA" and "DS" watthour meters, manufactured by the Canadian Westinghouse Company Limited, Hamilton, Ontario.


Rating of Apparatus: These registers may be used with any approved rating of types "DA" and "DS" watthour meters.

Description: These cyclometer registers feature large numbers for easy reading and a "kick-over" action for keeping the numbers centered. A finger-operated gear de-mesh permits fast register reset.

E. F. Power,  
Assistant Director (E&G),  
Standards Division.

R. W. MacLean,  
Director,  
Standards Division.

Ref: A-545A



CANADIAN WESTINGHOUSE CYCLOMETER REGISTER  
FOR USE WITH TYPES "DA" AND "DS" SINGLE-PHASE WATTHOUR METERS

