

TRADE AND COMMERCE
CANADA

STANDARDS DIVISION

OTTAWA, November 9, 1956.

MODIFICATION OF TYPE APPROVALSANGAMO TYPE "LP" VOLTAGE TRANSFORMERS


The modification to the apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and the modified apparatus may be admitted to verification in Canada.

Apparatus Modified: Type "LP" Voltage Transformers, manufactured by the Sangamo Company Limited, Leaside, Toronto 17, Ontario.

Rating of Apparatus:

Voltage Rating	575 to 115	i.e. 5 to 1
	460 to 115	i.e. 4 to 1
	345 to 115	i.e. 3 to 1
	275 to 110 or 285 to 114 ..	i.e. 2.5 to 1
	230 to 115	i.e. 2 to 1
	115 to 115	i.e. 1 to 1
Accuracy Class	1.2 W.	
Frequency	60 cycles	
Insulation Class	0.6 KV.	

Modification: Type "LP" voltage transformers were originally approved under Approval Circulars SD-EA.1, August 5, 1947 and SD-EA.214, October 13, 1955. The modification consists of a new nameplate, the essential change consisting of the addition of the accuracy class rating and the deletion of the burden rating.


R. W. MacLean
Director,
Standards Division.

E. F. Power

E. F. Power,
Assistant Director (E&G),
Standards Division.

Ref: A-601

