



## STANDARDS DIVISION

OTTAWA, November 29, 1956.

TYPE APPROVALPACKARD TYPE "E2.5 SPECIAL" CURRENT TRANSFORMER

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.

Apparatus Approved: Type "E2.5 Special" Current Transformer, manufactured by the Packard Electric Company Limited, St. Catharines, Ontario.

## Rating of Apparatus:

Primary Current .....	30 amperes
Secondary Current .....	5 amperes
Voltage Rating .....	2.5 KV dry, 5 KV oil-insulated
Accuracy Rating: 60 cycles ...	0.3B0.1, 0.3B0.5 <sup>*</sup> , 0.3B0.9, 0.6B2.0
25 cycles ...	0.3B0.1, 0.3B0.5, 0.3B0.9, 0.6B2.0
Frequency .....	25-60 cycles
Style .....	Type "E2.5 Special"

\* shown on data sheet for Metering Equipment.

Description: The type "E2.5 Special" current transformer in various primary ratings from 5 to 600 amperes was approved under Circular SD-EA.232 of March 7, 1956. This range of ratings is now extended to include the 30-5 ampere rating approved herein.

*E. F. Power*

E. F. Power,  
Assistant Director (E&G),  
Standards Division.

*R. W. MacLean*  
R. W. MacLean,  
Director,  
Standards Division.

Ref: A-547A

