



TRADE AND COMMERCE
CANADA

SD-EA.286

STANDARDS DIVISION

OTTAWA, March 20, 1957.

TYPE APPROVAL

FERRANTI TYPES "FMXA" AND "FMXS"
WATTHOUR METERS

The apparatus specified herein has been duly approved by the Standards Division under the provisions of the Electricity Inspection Act, Chapter 94, R.S. 1952, and may be admitted to verification in Canada.


Apparatus Approved: Types "FMXA" and "FMXS" Single-Phase Watthour Meters, manufactured by Ferranti Electric Limited, Mount Dennis, Toronto 15, Ontario.

Rating of Apparatus:

Ampere Range 0.75 - 100 amperes
Voltage 230 or 240
Wire 3
Frequency 50 cycles
K_h 6

Description: These 50-cycle meters are identical with the 60-cycle meters previously approved in Circular SD-EA.200, dated June 3, 1955.

The approval also covers the conversion from a 2-wire meter (type "FMA" or "FMS") to a 3-wire meter (type "FMXA" or "FMXS") as described in Circular SD-EA.237, dated April 9, 1956.


R. W. MacLean,
Director,
Standards Division.



E. F. Power,
Assistant Director (E&G),
Standards Division.

Ref: A-633

